



July 7, 2023

RE: **RUMC Bi-Plane Cath Lab**
355 Bard Avenue
Staten Island, NY
GMS Project #21190

MEMO: ADDENDUM 1 STRUCTURAL DRAWINGS

The following are the revisions for the Addendum 1 structural drawings dated 07/07/2023.
Three (3) of the nine (9) structural drawings have revisions.
All changes are bubbled with a #1 triangle.

1. **Drawing S-101.00 Sheet 3 of 9 1st Floor Framing Plan:**
 - a. Added note for removal of existing brick and block wall at interface between existing Seton and Spellman Buildings.
 - b. Added Section 2: showing lintel requirement at wall removal.
2. **Drawing S-102.00 Sheet 4 of 9 2nd Floor Framing Plan:**
 - a. Added note for removal of existing brick and block wall (below) at interface between existing Seton and Spellman Building.
 - b. Added steel relieving angle at wall removal.
 - c. Added Section 2: showing existing lintel resupport detail where existing lintel has been cut by duct.
3. **Drawing S-104.00 Sheet 6 of 9 Roof Framing Plan:**
 - a. Plan #2 Dunnage Framing Plan: Added steel W8X18 air handling unit support steel at locations between unit modules. Net addition = two (2) steel W8x18 beams (four added, two deleted).

End of Narrative