Consultants

BOHLER //
2929 Expressway Drive North
Hauppauge, NY 11749
Phone: (631) 738-1200
Fax: (631) 285-6464
www.BohlerEngineering.com

Exceeding Your Expectations

Lizardos
Mechanical & Electrical Engineering
200 Old Country Road, Suite 670
Mineola, NY 11501
Phone: (516) 484-1020
Fax: (516) 484-0926
www.leapc.com

Key Plan   AREA OF WORK 2,715 SQ FT   NORTH

Notes

Revision	By	Appd.	YY.MM.DD

DOB FILING	GM	BD	23.10.16
OMEGA ENVIRONMENTAL SERVICES	GM	BD	23.05.01
OMH FILING	GM	BD	22.12.09
Issued		By	Appd.	YY.MM.DD

File Name: 000048_A-001 - Standard Mounting Heights.dwg

Dwn.	Chkd.	Dsgn.	YY.MM.DD

Permit-Seal

Client/Project
RICHMOND UNIVERSITY MEDICAL CENTER
TRANSFORMATION GRANT

669 CASTLETON AVE, STATEN ISLAND, NY
SECOND FLOOR PROPOSED RENOVATION

Title
STANDARD MOUNTING HEIGHTS

Project No.	Scale
225300004	

Drawing No.	Sheet	Revision

A-001.00   4 of 22

Drawing Details:

1. TYP. H/C WATER CLOSET ELEV. — 3/8" = 1'-0"
2. TYP. H/C WATER CLOSET ELEV. — 3/8" = 1'-0"
3. H/C W/C @ RECESSED SINK/LAV — 3/8" = 1'-0"
4. TYP. H/C WATER CLOSET PLAN — 3/8" = 1'-0"
5. TYP. H/C WATER CLOSET STALL PLAN — 3/8" = 1'-0"
6. TYP. H/C URINAL — 1/4" = 1'-0"
7. DETAIL AT H/C SHOWER SEAT — 3/4" = 1'-0"
8. TYP. H/C SHOWER (TRANSFER) — 3/8" = 1'-0"
9. TYP. H/C SHOWER PLAN (TRANSFER) — 3/8" = 1'-0"
10. TYP. H/C LAVATORY — 3/8" = 1'-0"
11. TYP. H/C DRINKING FOUNTAIN — 1/2" = 1'-0"
12. TYP. MOUNTING HTS. - MED. EQUP. — 1/2" = 1'-0"
13. TYP. MOUNTING HTS. @ DOORS — 1/2" = 1'-0"
14. TYP. TOILET ROOM DOOR — 1/2" = 1'-0"
15. TYP. MOUNTING HTS. @ EXIT DOOR — 1/2" = 1'-0"
16. TYP. MOUNTING HTS. - DISPENSERS — 1/2" = 1'-0"
17. TYP. MOUNTING HTS. - DEVICES — 1/2" = 1'-0"
18. TYP. MOUNTING HTS. - MISC. — 1/2" = 1'-0"
19. CHANGES IN FLOOR LEVEL — 12" = 1'-0"

TOILET ACCESSORIES NOTES:
1. G.C. TO SUPPLY AND INSTALL PIPE COVERS FOR ALL EXPOSED PIPING UNDER NEW LAVATORIES/SINKS.
2. G.C. TO SUPPLY AND INSTALL METAL BRACKETS OR APPROPRIATE BLOCKING NECESSARY FOR TOILET ACCESSORY INSTALLATION.
3. G.C. TO MAINTAIN FIRE RATING IF ACCESSORY IS RECESSED IN FIRE RATED PARTITION.