



**Technology Management Application/Fire Alarm Application
 Letter of Acceptance**

To: JOHN LIZARDOS
Record ID of previously Accepted /Approved application:

Issuance Date: 10/09/2023
Record ID: 2023-TMFALM-000954-PLAN

Premises: 669 Castleton Avenue Staten Island NY 10301
Block: 00101

BIN: 5002229
Lot: 0002
Work on Floor(s): CELLAR, 1ST, 2ND, ROOF
Job Number:

Filed with Agency: Not Applicable
Is Job filed on or before June 2nd, 2019?:
Dominant Occupancy: G: Education

Occupancy Classification of the area of work: E: 5 or more persons at any time for educational purposes

Other/Multiple Occupancy: G, E

Building Height (ft): 33 **Building Stories:** 2

Reviewed Under Construction Code: 2014

Other Reviewed Under Construction Code:

Sprinkler Information: Fully Sprinklered

Is Standpipe Protection Provided?: No

Identify Floor(s) Protected:

Seismic Design Category:

Indicate the Areas Protected:

Construction Classification:

Other Construction Classification:

Applicant Information

First Name: JOHN
Last Name: LIZARDOS
Business Name: LIZARDOS ENGINEERING
Address: 200 OLD COUNTY ROAD 670
 MINEOLA NY 11501
Business phone: 5164841020
Mobile Phone:
E-Mail: JOHN.LIZARDOS@LEAPC.COM
License Number: 075404
License Type: Professional Engineer

Building Owner Information

First Name: JOSEPH
Last Name: H
Business Name: RICHMOND UNIVERSITY MEDICAL
 CENTER
Address: 355 BARD AVE
 STATEN ISLAND, NY 10310-1664
Business Phone: (718)818-1905
Mobile Phone:
E-Mail: JEARL@RUMCSI.ORG
Doing Business As: AVP FACILITES

Job Description: Manual and automatic smoke/co detectors and sprinkler FAS.

The Fire Department has reviewed your fire alarm application and your application is hereby approved. The proposed fire alarm installation is subject to audibility & visibility throughout the premises.

Applicants must submit a request for Project Authorization via FDNY Business Portal to obtain a Project Authorization prior to commencement of the construction as per approved plans.

Note: Project Authorization not required for applications that are filed prior to Local Law 195 and involves a DOB "FA" work type applications.

This letter along with the approved plans shall be presented at the time of scheduling an inspection to the Fire Alarm Inspection Unit (FAIU). The final approval is subject to inspection.

In the interest of public safety, the Fire Commissioner may revoke, modify, or require additional safeguards not expressed in this letter.

Sincerely,
 Naznin Fancy
 Plan Examiner
 Naznin.Fancy@fdny.nyc.gov

By order of,
 Chief of Fire Prevention

